



Professional
Testing
Laboratory, Inc.

CA 01350 Test Report

Professionally Certified Green CA 01350 testing is conducted through Professional Testing Laboratory, Inc., an accredited ISO 17025 laboratory.

Company Name: **Capri Cork**
CA 01350 – Test Results VOC Emissions
Date: July 15, 2011

Product: Cork

On behalf of Professionally Certified Green, this product was tested for VOC emissions by test method – ASTM D5116 Modified Organic Emissions Testing. All chemicals of concern were found to be under the CA 01350 required criteria.

Test Results		Test Results	
Target Compound	Emission ($\mu\text{g}/\text{m}^3$)	Target Compound	Emission ($\mu\text{g}/\text{m}^3$)
Acetaldehyde	<5	Formaldehyde	<5
Benzene	<2	n-Hexane	<2
Carbon Disulfide	<2	Isophorone	<2
Carbon Tetrachloride	<2	Isopropanol	<2
Chlorobenzene	<2	Methyl Chloroform	<2
Chloroform	<2	Methylene Chloride	<2
1,4-Dichlorobenzene	<2	Methyl tert-butyl Ether	<2
1,1-Dichloroethylene	<2	Napthalene	<4
Dimethyl Formamide	<2	Phenol	<2
1,4-Dioxane	<2	Propylene glycol Monomethyl ether	<2
Epichlorohydrin	<1	Styrene	<2
Ethyl Benzene	<2	Tetrachlorethylene	<2
Ethylene Glycol	<2	Toluene	<2
E.G. Monoethyl ether	<2	Trichloroethylene	<2
E.G. Monoethyl ether acetate	<2	Vinyl Acetate	<2
Ethylene glycol Monomethyl ether	<2	Xylenes	<15
E.G. Monomethyl ether acetate	<2		

Report #: 247143

Approved By: _____

This document is provided for the exclusive use of the client for whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This document applies only to those samples tested and is not necessarily indicative of apparently identical or similar products. This document, or the name of Professional Testing Laboratory, Inc., shall not be used under any circumstances in advertising to the general public.