

*SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:*

## Gold Series

215 Bucky Dr., Lititz, PA, United States

For the following product(s):

### Flooring Adhesives:

MA 2000, MM 2000, AA 2010

The product(s) meets all of the necessary qualifications to be certified for the following claim:

### FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom, private office, and single-family residence parameters when modeled as Flooring. Also, conforms to the SCAQMD Rule 1168 - Adhesive and Sealants (October 2017).

Standard Product Application Amount: 100.0g/m<sup>2</sup>

Measured Concentration of Total Volatile Organic Compounds (TVOC): Between 0.5 – 5.0 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Methylene Chloride and Perchloroethylene are not intentionally added to certified products.

Registration # SCS-FS-05568

Valid from: October 1, 2019 to September 30, 2020

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ISO/IEC 17065  
Product Certification Body  
#0821



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President  
SCS Global Services

2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA